



Accepted Proprietary Treatment Systems for Use in Colorado On-Site Wastewater Treatment Systems (<2000 GPD)

Company Name	Product Name / Model	CDPHE Acceptance Date	Accepted Treatment Level	Notes
Bio-Microbics	MicroFast 0.5, 0.625, 0.75, 0.9, 1.5 RetroFast 0.375	3/5/15	TL2N	Each model is restricted by maximum daily flows specific to that unit; Blower requirements vary with elevation; Cold weather start-up may require heat source. Refer to WQCD letter.
Eliminite	TANC; 120, 220	4/27/15	TL2	Each model is restricted by maximum daily flows specific to that unit; Refer to WQCD letter for additional requirements.
Eljen	A-42 GSF, 12" Sand Base	3/23/15	TL2	Bed system = 24 sq.ft./mod.; Trench systems = 12 sq.ft./mod. (both subject to STA req's. of Table 10-1). Refer to WQCD letter
Norweco; Singulair	960 & TNT: 500,600, 750, 800, 1250, 1500	12/5/14	TL-2	Each model is restricted by maximum daily flows specific to that unit; Refer to WQCD letter for additional requirements.
Norweco; Singulair Green	960 & TNT: 500,600	12/5/14	TL-2	Each model is restricted by maximum daily flows specific to that unit; Refer to WQCD letter for additional requirements.
Orenco; Advantex	AX-20, AX-20RT, AX-25RT, AX-100	3/26/15	TL3N	System may be configured in Mode 1 or Mode 3 for TL2, TL2N, TL3. A mode 3 configuration is required for TL3N. Refer to WQCD letter for additional requirements